			***
REVISIONS			
DESCRIPTIONS	BY	DATE	APPROVED

- NOTE: 1. PRECAST PIPE, ADJUSTING RINGS AND TAPERED SECTIONS SHALL BE CONSTRUCTED IN ACCORDANCE WITH STATE STANDARDS FOR CLASS II REINFORCED CONCRETE.
  - 2. ALL JOINTS BETWEEN PRECAST SECTIONS SHALL BE MORTARED, INSIDE AND OUTSIDE.
  - 3. INTERIOR OF THE MANHOLE SHALL HAVE A SMOOTH TROWELED SURFACE.
  - 4. MANHOLE COVER SHALL HAVE THE WORDS "STORM SEWER" MOLDED INTO THE COVER, WITH PICK HOLE AND EDGE HOLE.
  - 5. PIPES LARGER THAN 48" REQUIRE A SPECIAL DESIGN.
  - 6. CONSTRUCT STORM DRAIN BOX WITH DECK AND KEY FOR PRECAST TAPERED CONE, FOR A FULL DECK BEARING ALL CONSTRUCTION JOINTS TO BE APPROVED BY CITY ENGINEER.

